WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23244
Permit No.
Basin

1. OWNER Ernest Mejia ADDRESS 1990 Armory drive Santa Rosa Calif. 95401
Parcel B Battlemountain

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 31 N/S R. 45 E. Lander County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	2	
Sandy Br.		2	22	
Gravel / clay		22	56	
Clay Brown		56	65	
Shale green		65	85	
Clay / Brown		85	92	
clay gray		92	118	
gravel		118	128	
clay		128	132	

Date started 7-30, 1981
Date completed 8-4, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	~~40~~	~~50~~	~~2 hrs~~

BAILER TEST
G.P.M. 40 Draw down 50 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 132 feet
Casing record 133
Weight per foot 156 Wall Thickness

Diameter	From	To
6 inches	0 feet	90 feet
5 9/16 inches	96 feet	132 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 51 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 6 x 1/4
From 113 feet to 133 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow 40 G.P.M.
Water temperature 54 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A. C. Stites
Address 7495 Cloudburst
Nevada contractor's license number # 016578
Nevada driller's license number # 1145
Signed A. C. Stites
Date

USE ADDITIONAL SHEETS IF NECESSARY

O-627