

OFFICE USE ONLY
 Log No. 23279
 Permit No.
 Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER RON SMITH ADDRESS 236 AUSTIN, NEV 89710
DRY CREEK FARMS
NW CORNER OF
 2. LOCATION SW 1/4 SW 1/4 Sec. 16 T. 19 N N/S R. 47 E. LANDER County
 PERMIT NO. 25916

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------------------------------------------|--------------|------|-----|------------|
| TOP SOIL | | 0 | 4 | 4' |
| SAND, CLAY & GRAVEL | | 4 | 10 | 6 |
| LG. GRAVEL & SAND ROCKS TO 4 & inc. | | 10 | 22 | 12 |
| CLAY W/SAND | | 22 | 28 | 6 |
| CLAY W/SAND | | 28 | 32 | 4 |
| SAND & GRAVEL | | 32 | 38 | 6 |
| COURSE SAND & GRAVEL | | 38 | 50 | 12 |
| CLAY W/GRAVEL | | 50 | 55 | 5 |
| LG. GRAVEL & ROCKS | | 55 | 75 | 20 |
| CLAY W/SAND & GRAVEL | | 75 | 85 | 10 |
| GRAVEL & SOME ROCKS TO 5 inc | | 85 | 107 | 22 |
| FINE SAND & GRAVEL | | 107 | 110 | 3 |
| SAND & GRAVEL SOME ROCKS TO 3 inc. STREAKS OF FINE SAND | | 110 | 155 | 45 |
| CLAY W/SAND & GRAVEL STREAKS | | 155 | 165 | 10 |
| SAND & LG. GRAVEL | | 165 | 200 | 35 |

8. WELL CONSTRUCTION
 Diameter hole 18 inches Total depth 200 feet
 Casing record 8
 Weight per foot 12.74 Thickness 10 ga.
 Diameter From To
8 BLANK inches 0 feet 100 feet
8 MILL SLOT inches 100 feet 200 feet
 inches feet feet
 inches feet feet
 inches feet feet
 inches feet feet
 Surface seal: Yes No Type CONCRETE
 Depth of seal 50 FEET feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 200 feet

Perforations:
 Type perforation ROSBOR MOSS MILL SLOT
 Size perforation 1/8
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Date started 7-19-81, 19.....
 Date completed 7-20-81, 19.....

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours

9. WATER LEVEL
 Static water level 90 Feet below land surface.
 Flow G.P.M.
 Water temperature ° F. Quality.

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BRAD SANTUCCI
6860 W. ROSECREEK ROAD
 Address WINNEMUCCA, NEV 89445
015234
 Nevada contractor's license number.
 Nevada driller's license number 1153
 Signed Brad Santucci
 Date 8-3-81