WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23287
Permit No.
Basin 105

1. OWNER Gary Casteel ADDRESS 581 Greenachers Rd parcel # 1219-23-002-014 Gardnerville Nev.

2. ~~LOCATION~~ Right un Corner of ¼ ¼ Sec. ~~22~~ 23 T. 12 N/S R. 19 E. Douglas County

PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Small gravel		0	100	100
- plugged by well log # 113940				
- See replacement well drilled under log # 113941				
38.881983°N NAD27				
119.807867°W				

Date started 8/21, 19 81
Date completed 8/22, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	60	0	2 Hr.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 ¾ inches Total depth 100 feet
Casing record 8 5/8
Weight per foot 12.89 Thickness 188

Diameter	From	To
8 5/8 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 100 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 99 Feet below land surface 1
Flow 5 G.P.M. 60
Water temperature Cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump + Drilling
Address 20805 Cooke Dr. Reno
Nevada contractor's license number 0122360
Nevada driller's license number 1001
Signed Ivan R. Strauss
Date 8/24/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627