WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23289
Permit No. 35376
Basin 859

1. OWNER Larry Olson ADDRESS 120 E Esmeralda Washoe City

2. LOCATION SW ¼ SW ¼ Sec. 32 T. ~~20~~ 17 (N)S R. ~~17~~ 20 E. Washoe County
PERMIT NO. 35376 C3200 East Lake Blv. New Washoe Sub. Div.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
D.G.		10	40	30
Soft Rock		40	160	120
Granite		160	182	22

Date started 8/27, 19 81
Date completed 8/28, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	18	0	24hr

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 182 feet
Casing record 8 5/8
Weight per foot ..... Thickness 1.26

Diameter	From	To
8 5/8 inches	0 feet	182 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 60' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 182 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 160 feet to 182 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 102 Feet below land surface 80
Flow 0 G.P.M. 18
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump & Drilling
Address 20805 Cooke Dr. Reno
Nevada contractor's license number 012236
Nevada driller's license number 1001
Signed Avon R. Stranger
Date 8/30/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627