WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23318
Permit No.
Basin

1. OWNER Mary Crozier ADDRESS 1820 Harte Rd
Virginia City Highlands Virginia City Highlands
Lot 89 Block M

2. LOCATION SE ¼ NW ¼ Sec. 5 T. 17 N/S R. 21 E. Storey County
PERMIT NO.

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy clay		0	1	1
grey rock		1	15	14
soft d. G.		15	28	13
hard Volcanic Rock		28	84	56
soft gray Rock		84	129	45
fractured Val. Rock	X	129	142	13
hard gray Rock	X	141	163	22
fractured Val. Rock	X	163	178	15

Date started 9/27, 19 81
Date completed 9/28, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 178 feet
Casing record
Weight per foot .15 Thickness .188

Diameter	From	To
6 5/8 O.d inches	0 feet	178 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type sand & cement
Depth of seal 67 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 67 feet to 178 feet

Perforations:
Type perforation factory sawed
Size perforation 3-32 X 2½"
From feet to feet
From 124 feet to 178 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 67 Feet below land surface
Flow G.P.M. 12
Water temperature Cold F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams
Address 22 So. Patterson Rd. Sparks Nev.
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul E Williams
Date 9/28/81

USE ADDITIONAL SHEETS IF NECESSARY

O-627