

OFFICE USE ONLY
 Log No. 23455
 Permit No. 35074
 Basin BB-PLEASANT V

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER THOMAS CREEK WATER CO. ADDRESS 888 West 2nd. Street, Reno Nevada
89503

2. LOCATION SW 1/4 SW 1/4 Sec. 7 T. 17 N/S R. 20 E. Washoe County
 PERMIT NO. State of Nevada permit #35074 75226

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	4	4
Boulder cemented w/brown clay		4	18	14
Green clay sandy		18	21	3
Smaller boulders & gravel		21	32	11
Boulders cemented w/brown clay		32	52	20
Big granite boulders		52	59	7
Boulders, granite & volcanic		59	110	41
Soft zone	x	110	119	9
Boulders, granite & volcanic		119	139	20
Soft zone, gravel & sand	x	139	147	8
Boulders		147	151	4

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 151 feet
 Casing record 151
 Weight per foot..... Thickness 188

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>151</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type cement
 Depth of seal..... 50 feet
 Gravel packed: Yes No
 Gravel packed from..... 50 feet to..... 151 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 8 around
 From..... 101 feet to..... 151 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started..... 11-16-81....., 19.....
 Date completed..... 11-27-81....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level..... 61 Feet below land surface.....
 Flow..... 100 G.P.M. w/air
 Water temperature..... cold ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name..... WAYNE DRILLING INC.
 Address..... P.O. Box 12370, Reno, Nevada 89510
 Nevada contractor's license number..... 14063
 Nevada driller's license number..... 923
 Signed..... Ed Mondragon
 Date..... 27 Nov. 1981

BAILER TEST

G.P.M..... Draw down..... feet hours
 G.P.M..... Draw down..... feet hours
 G.P.M..... Draw down..... feet hours