WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23484
Permit No. 44170 → 53822
Basin Eagle V. 104

1. OWNER Sierra Estates Developement ADDRESS Well Located on Buck Way ½ way between Shawnee (Jacks Valley) and Green Acres Drive.

2. LOCATION NW ¼ SW ¼ Sec. 6 T. 14 N/S R. 20 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG ~~+ Boulder~~ Sand		0	18	18
DG + Cobbles		18	37	19
Sand + Boulders	*	37	75	38
DG + Sand Streaks	**	75	190	115
Harder DG, some Loose streaks	*	190	255	65
Rotten Granite	—	255	270	15

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1	150	140	6
	148	140	12

Test could not Run straight thru Due to Complaining neighbors.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 28", 21 inches Total depth 270 feet
Casing record 271' x 10 3/4
Weight per foot ..... Thickness .250

Diameter	From	To
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☒ No ☐ Type Pumped Grout around 22" casing
Depth of seal ..... feet
Gravel packed: Yes ☒ No ☐
Gravel packed from Ø feet to 270 feet

Perforations:
Type perforation Stainless Steel Screen
Size perforation .070
From 80 feet to 90 feet
From 110 feet to 130 feet
From 150 feet to 170 feet
From 190 feet to 210 feet
From 230 feet to 250 feet

9. WATER LEVEL
Static water level 33 Feet below land surface
Flow ..... G.P.M. 150
Water temperature 50.1 °F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co.
Address 2210 Utah St.
Nevada contractor's license number 4739 A
Nevada driller's license number 794
Signed Jim V. Enloe
Date Sept. 18, 1981

USE ADDITIONAL SHEETS IF NECESSARY

O-627