

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER HAROLD L. WEST ADDRESS #2 FAHREN WAY
YERINGTON, NEVADA 89447

2. LOCATION S.E. 1/4 S1/2 1/4 Sec. 4 T. 13 N. R. 26 E. 14000 County _____
 PERMIT NO. _____

3. TYPE OF WORK	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	4. PROPOSED USE	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	5. TYPE WELL	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
	Deepen <input type="checkbox"/>	Other <input type="checkbox"/>		Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>		Other <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL (CLAY)		0	16	16
COARSE SAND AND CLAY		16	25	9
CLAY		25	60	35
COARSE SAND		60	65	5
CLAY		65	80	15
COARSE SAND AND GRAVEL	X	80	102	22

8. WELL CONSTRUCTION

Diameter hole 10 3/8 inches Total depth 102 feet
 Casing record _____
 Weight per foot _____ Thickness 188 156

Diameter	From	To
<u>6 3/8</u> inches	<u>(±) 1</u> feet	<u>10.1</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type NEAT CEMENT
 Depth of seal 50' PLUMED feet
 Gravel packed: Yes No
 Gravel packed from 50' feet to 101' feet

Perforations:
 Type perforation FABRY SAND
 Size perforation 3/32" x 3' x 6' rows
 From 81' feet to 101' feet
 From _____ feet to _____ feet

Date started 12-16, 1981
 Date completed 12-17, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>20</u>	<u>2.0</u>	<u>2</u> feet	<u>1/2</u> hour
_____	_____	_____ feet	_____ hours
_____	_____	_____ feet	_____ hours

BAILER TEST

G.P.M. <u>20</u>	Draw down <u>2</u> feet	<u>1/2</u> hour
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 12 Feet below land surface 15
 Flow _____ G.P.M. _____
 Water temperature 62.0 ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CRISTIAN BROS. DRILLING
102 N. 1345th LN.
 Address YERINGTON, NEVADA 89447

Nevada contractor's license number 15646
 Nevada driller's license number 870

Signed Billy Ogden
 Date 12-26-81