WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23529
Permit No.
Basin

1. OWNER Hawthorne utilities ADDRESS Corey Canyon

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 9 N/S R. 30 E. Mineral County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
D.G. - loam - some boulders scattered		4	72	68
greenish hard Rock fractured	x	72	185	113
Bluish hard Rock fractured		185	420	235
in and out of Blue & green Rock Fractured		420	680	260

T.D 680

Date started 12-8, 1981
Date completed Drilling completed ~~12-30~~, 19~~81~~ 1-3-82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	120	220	24
tested 1-17-82 Rmcheal			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION 10 5/8" for 82
Diameter hole 6 1/8 inches Total depth 680 feet
Casing record
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+ 3 feet	86 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Bentonite
Depth of seal 86 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 38 Feet below land surface
Flow 84 G.P.M.
Water temperature Cold 60° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling and Well Service
Address 2255 Glendale ave - Sparks
Nevada contractor's license number 15291
Nevada driller's license number 817
Signed Frank Padilla
Date 1-4-82

USE ADDITIONAL SHEETS IF NECESSARY

O-627