WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 23565
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER KEN SMITH ADDRESS 15200 Callahan Ranch Rd., Reno Nevada 89511

2. LOCATION ¼ ¼ Sec. 2 T. 17 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black top soil w/ boulders		0	3	3
Granite boulders & brown clay		3	67	64
DG & brown clay		67	124	57
Soft zone, boulders, sand & gravel	x	124	145	21
Granite boulders		145	150	5
WB 135-145				

Date started 2-11-82, 19
Date completed 2-12-82, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 150 feet
Casing record 150
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 48'2" feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 48'2" feet to 150 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 120 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 100 Feet below land surface
Flow 20 G.P.M. air
Water temperature cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.
Address P.O. Box 12370, Reno Nevada 89510
Nevada contractor's license number 14043
Nevada driller's license number 923
Signed Edward Mondragon
Date Feb. 16, 1982

USE ADDITIONAL SHEETS IF NECESSARY

O-627