WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23588
Permit No.
Basin

1. OWNER WM DAILEY ADDRESS 3140 NYE LANE CARSON CITY NEV 89701

2. LOCATION NW ¼ SW ¼ Sec. 20 T. 17 N N/S R. 22 E STOREY County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ROCK-CLAY		0	3	3
BOULDERS		3	5	2
ROCK CLAY		5	45	40
BOULDER		45	47	2
ROCK-CLAY		47	130	83
BOULDER		130	132	2
ROCK-CLAY				
SAND-GRAVEL		132	293	161
SAND-GRAVEL WATER	293	293	339	46

Date started Dec. 2 1981
Date completed Jan. 22 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 17 Draw down 260 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 339 feet
Casing record 0 BLANK TO 299
Weight per foot 12.92 Thickness .188

Diameter	From	To
12 inches	0 feet	50 feet
8 inches	50 feet	293 feet
6 inches	293 feet	339 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation MACHINE
Size perforation 3/32
From 299 feet to 339 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 260 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HAE PUMPS
Address 5551 HYSOE #5
Nevada contractor's license number 15489
Nevada driller's license number 561-203
Signed James W Thompson
Date 2-25-82

USE ADDITIONAL SHEETS IF NECESSARY