WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23678
Permit No.
Basin

1. OWNER Leonard MC INTOSH ADDRESS 4780 Franktown Road Old 395 Hwy

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 16 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	1	1
Brown clays and cobbles - Waters		1	57	56
Salt + Pepper granite Fractured - Hard		57	204	147
T.D 204				
AIR LIFT at 600 CFM to Clean and develop				

Date started 4-14-, 1982
Date completed 4-27-, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
test pump at 80 gpm with Sub pump			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 124-119' WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 204 feet
Casing record
Weight per foot 22.36 Thickness .250

Diameter		From		To	
8 5/8	inches	+ 2	feet	204	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Slurry
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 204 feet

Perforations:
Type perforation Factory
Size perforation 3/32 X 3
From 144 feet to 204 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 12 Feet below land surface
Flow G.P.M. 80
Water temperature ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling + Well Service
Address 2255 Glendale ave
Nevada contractor's license number 15291
Nevada driller's license number 1132
Signed R M Thiel
Date 4-28-82

USE ADDITIONAL SHEETS IF NECESSARY

D-627