WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23696
Permit No.
Basin

1. OWNER NEVADA HOMES INC. ADDRESS 540 South Rock Blvd., Sparks NV 89502

2. LOCATION SE ¼ SE ¼ Sec. 10 T. 20N N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown clay		3	43	40
Brown clay with DG		43	101	58
Hard spot, granite		101	103	3
Brown clay with DG		103	106	3
Decomposed Granite broken	x	106	138	32
Green granite		138	140	2
Water Strata (106-135)				

Date started 5-1-82, 19
Date completed 5-1-82, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" x 6 inches Total depth 140 feet
Casing record 140
Weight per foot Thickness .156

Diameter	From	To
6 5/9 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 140 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 101 feet to 131 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 46 Feet below land surface
Flow 30 G.P.M. with air
Water temperature cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc.
Address P.O. Box 12370, Reno Nevada 89510
Nevada contractor's license number 14043
Nevada driller's license number 923
Signed Edward Mordinger
Date May 3, 1982

USE ADDITIONAL SHEETS IF NECESSARY

0-627

'82 MAY -6 A10:35
RECEIVED
STATE ENGINEERS OFFICE