WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 23709
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Lonnie Robnett ADDRESS 1450 Granety - Reno Nev

2. LOCATION SE ¼ SE ¼ Sec. 19 T. 19 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other not ☒

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	180	
DG ~~[illegible]~~ water	182	180	182	
Brown sandy clay	~~[illegible]~~	182	210	
Gray ~~[illegible]~~ clay		210	250	
Volcanic Rock		250	420	
Gray Clay		420	485	
Gray + Brown clay		485	650	
wood ~~[illegible]~~		650	675	
Gray + Red clay		650	1002	
with Find Rock				
Volcanic Rock Black		1002	1005	
Red Sinders		1005	1015	
Black + Brown +				
green volcanic		1015	1150	
gray sand stone		1150	1160	
Brown lime stone	1165	1160	1185	
with water	11885			
Gray sand ~~[illegible]~~				
stone		1185	1320	

Date started 3/1/82, 19
Date completed 4/10/82, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 + 6 inches Total depth 1320 feet
Casing record 1000 FT 8 in 320 of 6
Weight per foot 13 lb Thickness .156

Diameter	From	To
~~12¼~~ 8 5/8 inches	0 feet	1000 feet
~~8¾~~ 6 5/8 inches	~~[illegible]~~ 995 feet	1320 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type
Depth of seal 1000 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32
From 1099 feet to 1165 feet
From 1187 feet to 1209 feet
From 1231 feet to 1259 feet
From 1272 feet to 1320 feet
From feet to feet

9. WATER LEVEL
Static water level 120 Feet below land surface
Flow G.P.M. 150
Water temperature 177 °F. Quality Light Brown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 22 South Patterson
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul Williams
Date 4/12/82

USE ADDITIONAL SHEETS IF NECESSARY

O-627