

OFFICE USE ONLY  
 Log No. 23719  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER UFFE NIELSON ADDRESS 828 South Harvard Blvd., Los Angeles CA. 90005

2. LOCATION N<sub>2</sub> 1/4 NW 1/4 Sec. 17 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil-boulder (one)		0	2	2
DG, gravel, boulder with brown clay		2	20	18
Boulder		20	23	3
Brown clay, gravel, DG, small boulders		23	79	56
Boulder		79	84	5
Brown clay with gravel, DG, small boulders		84	160	76
Black clay		160	172	12
Soft zone	x	172	184	12
Black clay		184	210	26
Soft zone	x	210	216	6
Black clay		216	225	9
Water Strata (172-184)				
" " (210-216)				

8. WELL CONSTRUCTION

Diameter hole 10 x 6 inches Total depth 225 feet  
 Casing record 225  
 Weight per foot \_\_\_\_\_ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>225</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 225 feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 2 1/2 x 6 around  
 From 179 feet to 221 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-10-82, 19\_\_\_\_\_  
 Date completed 5-11-82, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 145 Feet below land surface  
 Flow 25 G.P.M. with air  
 Water temperature cold °F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc.  
 Address P.O. Box 12370, Reno Nevada 89510  
 Nevada contractor's license number 14043  
 Nevada driller's license number 923  
 Signed Edward Mardragon  
 Date May 12, 1982