

OFFICE USE ONLY
 Log No. 2373A
 Permit No. 34902
 Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER JOHN ETCHINEK ADDRESS P. O. BOX 423
SILVER STATE TRUCKING BATTLE MOUNTAIN, NEVADA 89820
REESE RIVER VALLEY

2. LOCATION SW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec 9 T. 29 N/S R. 44 E. M.D.M. LANDER County
 PERMIT NO. 34902

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
surface soil		0	15	15
dense rock w/fractures		15	160	115
decomposed		160	175	15
fractured		175	187	12
decomposed		187	195	8
fractured		195	214	19
decomposed		214	227	13
fractured & decomposed		227	307	80
fractured		307	353	46
dense rock		353	365	12
fractured		365	402	37
fractured & decomposed		402	460	58
fractured		460	650	190

8. WELL CONSTRUCTION

Diameter hole 18 5/8 inches Total depth 600 feet
 Casing record 12 3/4" od x .250 wall
 Weight per foot 33.38 Thickness.....

Diameter	From	To
<u>12 3/4</u> inches	<u>+1</u> feet	<u>600</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

 Surface seal: Yes No Type cement grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 600 feet
 Perforations:
 Type perforation milled
 Size perforation 1/8" x 3"
 From 300 feet to 600 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL

Static water level..... Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING CO., INC.
 Address 7800 N. VIRGINIA STREET RENO, NV
 Nevada contractor's license number 7462A
 Nevada driller's license number 774
 Signed F.P. Sage
 Date MAY 17, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
SAGE BROS DRILLING	DID NOT TEST	NOT TEST	PUMP THIS WELL

BAILER TEST

G.P.M..... Draw down.....feethours
 G.P.M..... Draw down.....feethours
 G.P.M..... Draw down.....feethours