WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23747
Permit No.
Basin

1. OWNER Hisashi Nakamato ADDRESS 3900 Warren Way Reno

2. LOCATION sw ¼ nw ¼ Sec. 25 T. 19N N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy loam		0	3	3
sand & gravel mixed with	15			
brown clay	"	3	45	42
brown clay	"	45	115	70
bluegrey clay mixed with	2			
sand		115	210	95
sand & gravel mixed with				
blue grey clay	35	210	240	30
Blue grey clay	35	240	245	5

Date started April 17, 19 82
Date completed April 27, 19 81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	20	10	1

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 245 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
8 inches	+1.6 feet	245 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation factory sawed
Size perforation 3/32 X 4
From 205 feet to 245 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow 20 G.P.M.
Water temperature 145 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name David E. Ballard
Address 15000 Perlite Dr. Reno
Nevada contractor's license number 14170
Nevada driller's license number 1274
Signed David E. Ballard
Date May 18, 1982

USE ADDITIONAL SHEETS IF NECESSARY

O-627