

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Lois Baum ADDRESS N. Hwy. 40 Winnemucca, Nv.

2. LOCATION 1/4 1/4 Sec. 11 T. 35 N. 37 E.  Humboldt County  
 PERMIT NO. ....

3. TYPE OF WORK	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	4. PROPOSED USE	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	5. TYPE WELL	Cable <input checked="" type="checkbox"/>	Rotary <input type="checkbox"/>
	Deepen <input type="checkbox"/>	Other <input type="checkbox"/>		Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>		Other <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	4	4
Sand-cemented brown		4	35	31
Clay-sandy brown		35	50	15
Gravel sm. brown		50	58	8
Clay brown		58	63	5
gravel brown		63	67	4
Sandy-clay brown		67	72	5
Gravel brown		72	76	4
Clay-sandy brown		76	94	18
Gravel brown		94	106	12
Gravel brown		106	112	6

8. WELL CONSTRUCTION

Diameter hole.....6 inches Total depth.....113 feet  
 Casing record.....  
 Weight per foot.....11 Thickness.....156

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>113</u> feet
.....inches	.....feet	.....feet

Surface seal: Yes  No  Type.....cement  
 Depth of seal.....70 feet  
 Gravel packed: Yes  No   
 Gravel packed from.....feet to.....feet

Perforations:  
 Type perforation.....Worich  
 Size perforation.....4 by 1/8  
 From.....94 feet to.....108 feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Date started.....3-24-81....., 19.....  
 Date completed.....3-28-81....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.....30..... Draw down.....23 feet .....1 hours  
 G.P.M..... Draw down.....feet .....hours  
 G.P.M..... Draw down.....feet .....hours

9. WATER LEVEL

Static water level.....Feet below land surface.....  
 Flow.....30 G.P.M.  
 Water temperature.....54 ° F. Quality.....good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name.....Stites Well Drilling  
 Address.....Cloudburst Winnemucca  
 Nevada contractor's license number.....016578  
 Nevada driller's license number.....1187  
 Signed.....Robert Stites  
 Date.....March 30, 1981 (5-28-82)