WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23879
Permit No.
Basin 108

1. OWNER CLARENCE MOREDA ADDRESS 140 FARRELL LN. YERINGTON, NEV. 89447

2. LOCATION SE ¼ SE ¼ Sec. 6 T. 14 (N) S R. 25 E. LYON County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN CLAY | | 0 | 7 | 7 |
| COARSE SAND | | 7 | 18 | 11 |
| BLUE CLAY + COARSE SAND | | 18 | 28 | 10 |
| COARSE SAND | | 28 | 35 | 7 |
| COARSE SAND + BROWN CLAY | | 35 | 42 | 7 |
| BROWN CLAY + COARSE SAND | | 42 | 52 | 10 |
| COARSE SAND | | 52 | 75 | 23 |
| COARSE SAND W/ BROWN CLAY STRATAS | | 75 | 85 | 10 |
| COARSE SAND + BROWN CLAY | | 85 | 100 | 15 |
| COARSE + FINE SAND | | 100 | 105 | 5 |
| BROWN CLAY + COARSE SAND | X | 105 | 175 | 70 |
| COARSE SAND | X | 175 | 185 | 10 |

Date started 6-3, 19 82
Date completed 6-12, 19 82

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| 3400 | 42 | 14' 6" | 3 HR. |

BAILER TEST
G.P.M. 30 Draw down 12 feet ½ hour
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 5/8" inches Total depth 186' feet
Casing record
Weight per foot Thickness 156, 188

| Diameter | From | To |
|---|---|---|
| 8 5/8" inches | (+) 1' feet | 185' feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type NEAT CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 185' feet

Perforations:
Type perforation FACTORY SAWED
Size perforation 3/32" x 3" x 8 ROWS
From 165' feet to 185' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8' 6" Feet below land surface 7' 6"
Flow G.P.M.
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name OGDEN BROS' DRILLING
Address 162 N. BYBEE LN. YERINGTON, NEV. 89447

Nevada contractor's license number 15646

Nevada driller's license number 870

Signed [signature]

Date 6-14-82

USE ADDITIONAL SHEETS IF NECESSARY

O-627