WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24030
Permit No.
Basin

No CARD?

1. OWNER Edith Cook ADDRESS Box 416 Elko 89801

West Bullion Rd. Elko, NV

2. LOCATION NW ¼ NW ¼ Sec. 28 T. 34 N/S R. 55 E. Elko County

PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	12	12
Sand	✓	12	36	24
Red clay		36	40	4
Sand (bad water)	✓	40	52	12
Black shale		52	70	18
Light shale		70	115	45
Sand	✓	115	130	15
Clay (shale)		130	132	2
T.D. 132				

Date started 8/5, 1982
Date completed 8/12, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 gpm Draw down 11 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" & 8" inches Total depth 132 feet
Casing record 133 x 6 5/8"
Weight per foot 12.92 Thickness .188

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 132 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8" x 3"
From 112 feet to 132 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 12 Feet below land surface
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Amos Stockton & James W. Muth Muth Drilling Co.
Address Far. 203 Pine Street Elko, Nevada 89801

Nevada contractor's license number 10819

Nevada driller's license number 922 & 1202

Signed James V. Muth (632)

Date 8/26/82

USE ADDITIONAL SHEETS IF NECESSARY

O-627