Log No. 24045
Rec. ..... 19.....
Well No. 35975
Permit No. .....
Do not fill in.

RECEIVED
APR 24 1969
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Hardyn Lange

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner ~~Homer La Porte~~ DALE + MILLIE FINE Driller H. V. Weimer

Address 1510 So. Casino Dr. Las Vegas, Nevada, 89104 Address 9051 Mohawk Ave. Las Vegas, Nevada 89103 Lic. No. 171

NE 1/4-SE 1/4

Location of well: SE ¼ NE ¼ Sec. 24, T. 22 N/S, R. 60 E, in Clark County

or .....

Water will be used for Domestic Total depth of well 400 feet

Size of drilled hole 0 to 50' 12"-50' to 400' 10 Weight of casing per linear foot 121/2#

Thickness of casing ********** .134 Temp. of water 65 degrees

Diameter and length of casing 8 5/8" O.D. X 400'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure .....

If nonflowing well give depth of standing water from surface 235 feet

If flowing well describe control works .....
(Type and size of valve, etc.)

Date of commencement of well November, 25, 1968 Date of completion of well April, 4, 1969

Type of well rig Cable tool

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	2	2	Top soil
2	6	4	Hard pan
6	40	34	Cemented gravel
40	44	4	Lime shell
44	160	116	Cemented gravel
160	165	5	Hard lime shell.
165	240	175	Cemented gravel
240	265	15	Pink clay with little sand.
265	310	45	Cemented gravel.
310	345	35	Cemented gravel with loose sand occasionally.
345	400	55	Cemented gravel with showings of black loose gravel laminations.

Water-bearing Formation, Casing Perforations, etc.

Chief aquifer (water-bearing formation)

from 345 to 400 ft.

Other aquifers 310' to 345'

First water at 250 feet.

Casing perforated

from 350 to 400 ft.

Size of perforations

3/16" X 5"

(OVER)

919

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
5/8"O.D.	0	400	400	Cemented from 0 to 55'

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed H. U. Weimer
Well Driller

By.....

License No. 171

Dated April 23, 1969

(Not to be filled in by Driller)