

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Harry Williams/Witt Properties ADDRESS 612 Humboldt St., Reno, Nevada
(Sun Valley Project)

2. LOCATION S¹/₂ NE¹/₄ and N¹/₂ SE¹/₄
S¹/₂ x 1/4 1/4 Sec. 6 T. 20N. N/S R20E E. Washoe County
 PERMIT NO. W-060

3. TYPE OF WORK	4. PROPOSED USE	Hole No. <u>4</u>	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input checked="" type="checkbox"/>		Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>		Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	
Hard Pan		3	5	
Brown Clay		5	200	
Brown Clay Coarse				
Sand & Gravel		200	255	
Light Gray Clay		255	267	
Light Gray Clay & Large Boulders		267	272	
Gray Clay, Sand & Gravel		272	295	
DG		295	380	
DG, Large Boulders		380	405	
DG, Boulders & Clay		405	414	

8. WELL CONSTRUCTION

Diameter hole 20 inches Total depth 414 feet

Casing record.....

Weight per foot..... Thickness.....

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>335</u> feet
<u>10</u> inches	<u>335</u> feet	<u>414</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type.....

Depth of seal..... feet

Gravel packed: Yes No

Gravel packed from..... feet to..... feet

Perforations:

Type perforation 1/8 x 3" Factory

Size perforation.....

From..... feet to..... feet

Date started project Jan, 19 81
 Date completed project July, 19 82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
TESTING DONE BY			
SEA ENGINEERS			
SEE THEIR REPORT			

BAILER TEST

G.P.M.	Draw down	feet	hours
.....
.....
.....

9. SEE ENGINEERS REPORT

WATER LEVEL

Static water level..... Feet below land surface.....

Flow..... G.P.M.....

Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Burroughs of Nevada

Address 10310 Old Virginia City Rd.
Reno, Nevada 89511

Nevada contractor's license number 5092

Nevada driller's license number 611

Signed Wayne Burroughs

Date 8-23-82