WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24087
Permit No.
Basin

1. OWNER Robert Carrington ADDRESS Lot #49 Hyland Drive Virginia Highlands Sub

2. LOCATION NW ¼ NW ¼ Sec. 8 T. 17 N/S R. 21 E. Storey County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Yellow Andesite + clay		0	115	115
Grey Andesite		115	172	57
Fractured Grey Andsite	* 2gpm	172	178	6
Grey Andesite		178	272	94
Fractured Grey Andesite	* 3gpm	272	279	7
Grey Andesite		279	315	36

Date started Aug 31, 19 82
Date completed Sept 5, 19 82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pumping
Air lift	5	—	2
	3		8

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10", 8½" inches Total depth 304 feet
Casing record 305 x 6¼
Weight per foot Thickness .188

Diameter	From	To
6¼ inches	+1 feet	305 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 304 feet

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From 180 - 205 feet to 25 feet
From 205 - 225 feet to 20 feet
From 245 - 304 feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 170 Feet below land surface
Flow G.P.M. 3
Water temperature Cool °F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co.
Address 2510 Utah St
Nevada contractor's license number 4739 A
Nevada driller's license number 794
Signed [signature]
Date Sept. 13, 1982

USE ADDITIONAL SHEETS IF NECESSARY

0-627