WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24098
Permit No.
Basin

1. OWNER DE WITT MAZNE ADDRESS #5 PANPUESTA CIRCLE YERINGTON, NEV.

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 15 N S R. 25 E. LYON County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	6	6
FINE SAND		6	11	5
BROWN CLAY		11	13	2
FINE + COARSE SAND		13	16	3
BROWN CLAY + COARSE SAND		16	19	3
COARSE SAND		19	34	15
COARSE SAND + GRAVEL		34	49	15
COARSE SAND, GRAVEL w/ CLAY		49	57	8
COARSE SAND		57	59	2
BLUE CLAY + GRAVEL		59	74	15
COARSE SAND		74	79	5
BROWN CLAY + SAND		79	127	48
BROWN CLAY + GRAVEL		127	129	2
BLUE CLAY + GRAVEL		129	132	3
FINE + COARSE SAND		132	144	12
BROWN & BLUE CLAY W/ SAND		144	159	15
COARSE SAND + GRAVEL	X	159	164	5
BROWN CLAY + GRAVEL		164	174	10
COARSE SAND	X	174	184	10
COARSE SAND + BROWN CLAY	X	184	189	5
BROWN CLAY + COARSE SAND		189	192	3

Date started 9-16, 1982
Date completed 9-23, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	100	10'6"	2 HRS.

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 16" inches Total depth 193' feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
8 5/8" inches	(4) 1 feet	192 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 192' feet

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3/32" x 3" x 8 ROWS
From 152' feet to 192' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 54' Feet below land surface 3'
Flow — G.P.M. —
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name OGDEN BROS DRILLING
Address 162 N. BYERS LN. YERINGTON, NEV. 89447

Nevada contractor's license number 15646

Nevada driller's license number 870

Signed [signature]

Date 9-27-82

USE ADDITIONAL SHEETS IF NECESSARY

O-627