

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER BOB CLIER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 6645 Lot #9-N
Incline Village, NV 89450
 2. LOCATION NE 1/4 NW 1/4 Sec 32 T 18N N/S R 21 E Storey County
Virginia City Highlands
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	9	9
Yellow clay		9	20	11
Gray clay		20	120	100
Purple caly, soft zone		120	130	10
Gray clay		130	190	60
Light purple rock, soft		190	220	30
Light gray rock some clay streaks		220	310	90
Purple rock		310	330	20
Fracture	x	330	335	5
Gray rock		335	350	15
Water Strata (330-335)	20	GPM		

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 350 feet
 Casing record 350
 Weight per foot _____ Thickness .156
 Diameter 6 5/8 inches From 0 feet To 350 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 350 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 313 feet to 350 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 170 feet below land surface
 Flow 20 G.P.M. with air _____ P.S.I.
 Water temperature cold ° F. Quality _____

Date started 9-13-82, 19_____
 Date completed 9-20-82, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, Nevada 89510 Contractor
 Nevada contractor's license number 14043
 Nevada contractor's drillers number 908
 Nevada driller's license number 923 Actual Driller
 Signed Sary P. Hedman Contractor
 Date September 22, 1982

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours