

Log No. 24118
Permit No. _____
Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Nevada Ceres ADDRESS Elko Nevada

2. LOCATION SE 1/4 NE 1/4 Sec. 21 T. 34 N/S R. 55 E. Elk County _____
PERMIT NO. 36467

3. TYPE OF WORK			4. PROPOSED USE			5. TYPE WELL							
New Well	<input checked="" type="checkbox"/>	Recondition	<input type="checkbox"/>	Domestic	<input checked="" type="checkbox"/>	Irrigation	<input checked="" type="checkbox"/>	Test	<input type="checkbox"/>	Cable	<input type="checkbox"/>	Rotary	<input checked="" type="checkbox"/>
Deepen	<input type="checkbox"/>	Other	<input type="checkbox"/>	Municipal	<input type="checkbox"/>	Industrial	<input type="checkbox"/>	Stock	<input type="checkbox"/>	Other	<input type="checkbox"/>		<u>Fin</u>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sail		0	7	
Coarse gravel	X	7	47	
Blue clay with thin brittle layers		47	90	
Soft white clay		80	91	
Blue clay		91	92	
Black sandstone	X	92	95	
Blue clay with thin sandstone	X	95	130	
Coarser sandstone	X	130	137	
Blue clay with thin sandstone layers	X	137	200	

Water Temp. 55 to 120

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 200 feet
Casing record _____
Weight per foot _____ Thickness 1.88

Diameter	From	To
<u>6</u> inches	<u>1</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Best Cement
Depth of seal 55 feet
Gravel packed: Yes No
Gravel packed from 55 feet to 200 feet

Perforations:
Type perforation Factory milled
Size perforation 1/8 x 3"
From 120 feet to 200 feet
From _____ feet to _____ feet

Date started 9/16/82
Date completed 9/23/82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Fin</u>	<u>100+</u>	<u>180</u>	<u>4</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 8 Feet below land surface 8
Flow _____ G.P.M.
Water temperature * ° F. Quality GOOD

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.D. Reynolds
Address Walla, Ne
Nevada contractor's license number 014410
Nevada driller's license number 716
Signed [Signature]
Date 10/3/82