

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT No. 757

PRINT OR TYPE ONLY

1. OWNER ELVERA MEAD ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 11975 Heart Pine
Reno, Nevada 89506
 2. LOCATION SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 15 T. 21N N/S R. 19 E Washoe County
Lemmon Valley
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Brown sandy clay		210	260	50
Coarse gravels	x	260	265	5
Brown sandy clay		265	275	10
Water Strata (260-265)				

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 275 feet
 Casing record 275
 Weight per foot _____ Thickness .137

Diameter	From	To
<u>5</u> inches	<u>210</u> feet	<u>275</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type N/A
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation factory sawed slotw
 Size perforation 3/32 x 2 1/2 x 6 around
 From 248 feet to 275 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 165 feet below land surface
 Flow 30 G.P.M. with air P.S.I.
 Water temperature cold °F. Quality _____

Date started 10-1-82, 19_____
 Date completed 10-1-82, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno Nevada 89510
 Contractor
 Nevada contractor's license number 14043
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
 Actual Driller
 Signature Sergel Helman
 Contractor
 Date October 4, 1982

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours