

Log No. 24262  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1047

PRINT OR TYPE ONLY

1. OWNER William Adams ADDRESS AT WELL LOCATION E. Valley Rd  
MAILING ADDRESS 1800 Kings Rd & Two Bell  
Newport Beach, Calif.  
2. LOCATION  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 14 T. 13 N/S R. 20 E Douglas County  
PERMIT NO. 32C Old Dangers Estates Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & sand		0	6	
Clay		6	37	
Clay & Cobble stones		37	61	
Clay		61	66	
Clay & sand	X	66	68	
Clay		68	87	
Clay & Pea Gravel	X	87	89	
Clay		89	112	
Sandy clay		112	121	
Sand & Gravel	X	122	145	

8. WELL CONSTRUCTION

Diameter hole 8 7/8 inches Total depth 145 feet  
Casing record 145'  
Weight per foot \_\_\_\_\_ Thickness 1.88  
Diameter From To  
8 7/8 inches 1 feet 145 feet  
\_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
Surface seal: Yes  No  Type Grout Cement  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Perforations:  
Type perforation Factory slot  
Size perforation 3x1/16  
From 120 feet to 143 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 56 feet below land surface  
Flow \_\_\_\_\_ G.P.M. 40 P.S.I.  
Water temperature Cold ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Hi-Sierra Drilling Contractor  
Address Box 901 Minden, Nev. Contractor  
Nevada contractor's license number \_\_\_\_\_  
Nevada contractor's drillers number \_\_\_\_\_  
Nevada driller's license number 763 Actual Driller  
Signed Tony Kawchuck Contractor  
Date 11-8-82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>21 1/2</u>		

BAILER TEST

G.P.M. 40 Draw down 21 feet 2 1/2 hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours