

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 759

1. OWNER CHURCH of NAZARENE Rev. Warren A. Benoit ADDRESS AT WELL LOCATION 540 Del Monte Lane  
 MAILING ADDRESS 231 E 6th street Reno, Nevada 89501 Reno, Nevada 89511  
 2. LOCATION NW 1/4 SE 1/4 Sec. 36 T. 18N N/S R. 19 E. Washoe County  
 PERMIT NO. 40-162-28 19 SW Reno area  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black clay		0	23	23
Yellow clay, some gravels		23	29	6
Brown sandy clay		29	35	6
Yellow clay, some sand		35	40	5
Brown sandy clay		40	110	70
Brown clay small gravel		110	120	10
Soft zone, gravel & sand X		120	130	10
Gravel & sand with brown clay streaks		130	147	17
Brown clay		147	152	5
Water Strata (120+130)				

8. WELL CONSTRUCTION  
 Diameter hole 10 x 8 inches Total depth 152 feet  
 Casing record 152  
 Weight per foot \_\_\_\_\_ Thickness 1.188  

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>152</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type cement  
 Depth of seal 53 feet  
 Gravel packed: Yes  No   
 Gravel packed from 53 feet to 152 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32x2 1/2 x 8 around  
 From 109 feet to 149 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 11-15-82, 19\_\_\_\_  
 Date completed 11-18-82, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 3 feet below land surface  
 Flow 50 G.P.M. with air P.S.I.  
 Water temperature COLD ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
 Contractor  
 Address P.O. Box 12370, Reno, Nevada 89510  
 Contractor  
 Nevada contractor's license number 14043  
 Nevada contractor's drillers number 908  
 Nevada driller's license number 923  
 Actual Driller  
 Signed Sary C. Fedman  
 Contractor  
 Date November 29, 1982