CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

Well Ayindon

OFFICE USE ONLY
Log No. 24310
Permit No. 31287
Basin LEMMON VALLEY (EASTERN PART)

1. OWNER Skyline Mobil Home PARK
MAILING ADDRESS 7900 N. Virginia
Reno 89506

NOTICE OF INTENT NO.
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 15 T. 20 N N/S R. 19 E WASHOE County
PERMIT NO. 31287 Water Resources
Parcel No.
Subdivision Name

3. TYPE OF WORK
Redrill New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy gravel		0	46	46
Decayed granite		46	138	92
fractured Vol. Rock		138	146	8
Medium Hard Volcanic Rock		146	193	47
Hard gray granite		193	307	114
fractured granite		307	348	41
Hard granite		348	351	3

Date started 12-9 1982
Date completed 12-12 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3400	300	126 ft	24.5

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 351 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
8 5/8 o.d. inches	0 feet	351 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement grout
Depth of seal 150 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 150 feet to 351 feet

Perforations:
Type perforation factory sawed
Size perforation 3/32 x 2½ Double Row
From feet to feet
From feet to feet
From 307 feet to 351 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 215 feet below land surface
Flow G.P.M. 300 to 500
Water temperature 56 °F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams Sons (Contractor)
Address 22 So. Pattison, Sparks (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957 (Actual Driller)
Signed Paul E. Williams (Contractor)
Date 12-15-82

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434