

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety.

NOTICE OF INTENT NO. \_\_\_\_\_  
 ADDRESS AT WELL LOCATION 505 Mile Circle Drive  
Reno, Nevada 89511

1. OWNER E. G. BAILEY  
 MAILING ADDRESS 1955 VILLA WAY SO.  
RENO, NV. 89509

2. LOCATION NW ¼ SW ¼ Sec 7 T. 18 N/S R. W E Washoe County  
 PERMIT NO. \_\_\_\_\_ Intent Card No. 2003  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	6	6
Hard fractured boulders, granite		6	11	5
Sands from fine to coarse multi-colored with stringers of brown clay		11	71	60
Hard rock layer - granite		71	77	6
Coarse sands, blue white, brown - some tan clay		71	138	67
Blue clay with coarse sands - white & black		138	146	8
T.D. of Hole 146 ft.				
Casing string has a 6' blank on bottom for development				

8. WELL CONSTRUCTION  
 Diameter hole 8 3/4 inches Total depth 141 feet  
 Casing record 6 5/8  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>141</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Slurry  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to 141 feet

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 X 3"  
 From 135 feet to 114 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 16' feet below land surface  
 Flow 30 + G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool ° F. Quality good

Date started 12-30, 1982  
 Date completed 1-3, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Pumped Well at 20 GPM to clean and develop for two hours.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE, INC.  
 Contractor  
 Address 2255 GLENDALE AVE. - SPARKS, NV.  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller  
 Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date January 7, 1983