

Log No. 28349
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2004

PRINT OR TYPE ONLY

1. OWNER JOHN SILLONIS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 855 Glen Vista Dr. 5016 Pleasant View Dr.
Sparks, Nv. 89431 Sparks, Nv. 89431
 2. LOCATION SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 38 T. 27 N. 19 E. Washoe County
 PERMIT NO. 030-202-01 LOT # 7, UNIT # 2 SUBDIVISION NAME SUNSET VIEW RANCH HO 12 SPARKS
 Issued by Water Resources Parcel No. _____ Subdivision Name (FROM INTENT CARD)

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Redish Volcanic Rock & Tan Clays, Some Black Chip		0	205	
Soft Tan & Yellow Clay		205	230	
Fractured Rock-Redbrown and Black		230	238	
Volcanic Sands-Multi-colored		238	355	
Some Rock layers - Redish with clays-multi-colored sand		355	406	
Tan Clay		406	408	
Gray & Black Rock - fractured	X	408	416	
Sands-Coarse gray, yellow tan-redish	X	416	425	
T.D. 425 ft.				
Casing has 9' blank cellar at bottom for development.				

8. WELL CONSTRUCTION
 Diameter hole 8 3/4 inches Total depth 422' feet
 Casing record 6 5/8
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1.5</u> feet	<u>422</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout
 Depth of seal 55' feet
 Gravel packed: Yes No
 Gravel packed from 55 feet to 422 feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From 371 feet to 413 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 322 feet below land surface
 Flow _____ G.P.M. 15 P.S.I.
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING & WELL SERVICE
 Contractor
 Address 2255 GLENDALE AVE. - SPARKS, NV.
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller
 Signed Roger M. Thrall
 Roger M. Thrall Contractor
 Date 1-17-83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well at 150 PSI at 650 CFM for 3 hrs. to clean and develop.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours