

OFFICE USE ONLY  
 Log No. 24350  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 772

1. OWNER JOHN NEWMAN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 7575 Tholl Road \_\_\_\_\_  
Reno, Nevada 89506 \_\_\_\_\_  
 2. LOCATION SE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 4 T. 20N N/S R. 19 E \_\_\_\_\_  
Lemon Valley \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

| Material                       | Water Strata | From | To  | Thick-ness |
|--------------------------------|--------------|------|-----|------------|
| Top soil, some gravel and sand |              | 0    | 8   | 8          |
| Brown sandy clay               |              | 8    | 65  | 57         |
| Brown clay with gravel mixed   |              | 65   | 101 | 36         |
| DG                             |              | 101  | 108 | 7          |
| Gray granite                   |              | 108  | 120 | 12         |
| Fractured granite              | x            | 120  | 123 | 3          |
| Gray hard granite              |              | 123  | 125 | 2          |
| Water Strata (120-123)         |              |      |     |            |

8. WELL CONSTRUCTION  
 Diameter hole 10 x 6 inches Total depth 125 feet  
 Casing record 125  
 Weight per foot \_\_\_\_\_ Thickness .156  
 Diameter 6 5/8 inches From 0 feet To 125 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 125 feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 2 1/2 x 6 around  
 From 105 feet to 125 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1-20-83, 19\_\_\_\_  
 Date completed 1-20-83, 19\_\_\_\_

9. WATER LEVEL  
 Static water level 45 feet below land surface  
 Flow 20 G.P.M. with air P.S.I.  
 Water temperature cold ° F. Quality \_\_\_\_\_

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down  | After Hours Pump |
|----------|--------|------------|------------------|
|          |        | <u>21'</u> |                  |
|          |        |            |                  |
|          |        |            |                  |

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno Nevada 89510 Contractor  
 Nevada contractor's license number 14043  
 Nevada contractor's drillers number 908  
 Nevada driller's license number 923 Actual Driller  
 Signed [Signature] Contractor  
 Date January 24, 1983

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours