

**WELL DRILLERS REPORT**

NOTICE OF INTENT NO. \_\_\_\_\_  
 ADDRESS AT WELL LOCATION 232 S. Crook Rd

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER T. Gallagher ADDRESS AT WELL LOCATION 232 S. Crook Rd  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION New 1/4 New 1/4 Sec 33 T. 19 N/S R. 29 E Churchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	5	5
Clay		5	9	4
Yellow Sand		9	13	4
Clay		13	19	6
Brown silt		19	24	5
Brown clay		24	29	5
Grey clay		29	30	1
Green silt		30	34	4
Green clay		34	39	5
Green clay		39	42	3
Grey clay		42	47	5
Black sand		47	51	4
Black clay		51	67	16
Grey sand		67	69	2
Grey clay		69	72	3
Small Grey gravel		72	77	5
Grey clay		77	80	3
Sand		80	83	3
Clay		83	87	4
Brown clay		87	92	5
Large Gravel		92	100	8
Brown silt		100	103	3

8. WELL CONSTRUCTION  
 Diameter hole 8 5/8 inches Total depth 103 feet  
 Casing record 8 5/8 x 103  
 Weight per foot 16.94 Thickness 1.88  

Diameter	From	To
<u>12 1/4</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 5/8</u> inches	<u>50</u> feet	<u>103</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation machine slot  
 Size perforation 3/32 x 2 1/2  
 From 91 feet to 101 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

Date started 1-18, 1983  
 Date completed 1-28, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>Air Blow @ 15 G.P.M.</u>		

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Contractor  
 Address Box 888 Contractor  
 Nevada contractor's license number 11752  
 Nevada contractor's drillers number 772  
 Nevada driller's license number 772 Actual Driller  
 Signed W. Buffle Contractor  
 Date 1-28-83

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours