

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1756

PRINT OR TYPE ONLY

1. OWNER VERNON ANDREA ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS STAR RT
LOVELOCK, NEV 89419
 2. LOCATION NE 1/4 NW 1/4 Sec 9 T. 29 N/S R. 33 E PERSHING County
 PERMIT NO. 43201 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY TOP SOIL		0	12	12
DECOMPOSED GRANIT WITH SOME CLAY		12	30	18
TIGHT SAND & I.G. GRAVEL		30	95	65
TIGHT GRAVEL W/DECOMPOSED GRANIT STRINGERS		95	150	55
TIGHT GRAVEL		150	200	50
TIGHT GRAVEL W/DECOMPOSED GRANIT STRINGERS		200	260	60
TIGHT GRAVEL		260	285	25
DECOMPOSED GRANIT		285	290	5
TIGHT GRAVEL		290	305	15
DECOMPOSED GRANIT		305	310	5
TIGHT GRAVEL		310	340	30

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 340 feet
 Casing record 8
 Weight per foot 16.79 Thickness 3/16

Diameter	From	To
8. BLANK inches	0	201
8. LOUVERED inches	201	301
_____ inches	_____	_____

 Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 340 feet
 Perforations:
 Type perforation ROSCOE MOSS SHUTTER SCREEN
 Size perforation 1/8
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From see ABOVE feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HUMBOLDT DRILLING & PUMP CO., INC.
P.O. BOX 592 Contractor
 Address WINNEMUCCA, NEV 89445
 Nevada contractor's license number 015234
 Nevada contractor's drillers number C-23
 Nevada driller's license number 795 Actual Driller
 Signed [Signature] Contractor
 Date 2-21-83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>470</u>	<u>135</u>	<u>8</u>

BAILER TEST

G.P.M.	Draw down	feet	hours