WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24423
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2339

1. OWNER RUTH SEYMOUR
MAILING ADDRESS Corner Virginia & Ackley
Wadsworth, Nevada

ADDRESS AT WELL LOCATION 2220 GILBERT DR.
RENO, NV. 89502

2. LOCATION NW ¼ NW ¼ Sec. 3 T. 20 N/S R. 24 E WASHOE County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy overburden		0	6	
Boulders & cobbles		6	86	
Layer of tan colored clay & gravels		86	91	
Boulders & cobbles, cemented with light tan clays and fine sands		91	145	
T.D. - 129 ft.				
There is 10' of gravel in bottom of casing.				
Casing has 4' blank on bottom of perforated pipe				

Date started 2/16 19 83
Date completed 2/20 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air lift Well to clean and develop			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
10 5/8" - 60'
Diameter hole 8 3/4 inches Total depth 145 feet
Casing record 6 5/8 .156
Weight per foot 10.78 Thickness .156

Diameter		From		To	
6 5/8	inches	+ 18"	feet	129	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes [X] No [ ] Type Slurry
Depth of seal 50 ft. feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 129 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 105 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow 15 G.P.M. P.S.I.G.
Water temperature cool °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICE (Contractor)
Address 2255 GLENDALE AVE. - SPARKS, NV. (Contractor's)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132 (Actual Driller)
Signed Roger M. Turall (Contractor)
Date 2/24/83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6 81) 0-627

83 FEB 25 A10:48

RECEIVED
STATE ENGINEERS OFFICE

5\50 93
5\10 93

5\54\93
ROGER W. [illegible]

1135
1135
1253

5552 CLEMDATE VALE - SAVAGE MA
VOID DRILLING 5 MEET SEBAIGE

1001
12
50

Perforated pipe
Casing has 4, plane on bottom of

of casing
There is 10, of gravel in bottom

T D - 156 ft

Fine sands
With light tan clays and
Boulders & coppies cemented

Clay & Gravels
Gravel of tan colored

Boulders & coppies

Sandy overburden

105 152
3\35 x 3
Factory

50 156
50 ft
xx
Sierra

9 5/8 + 12 152
10 ft 152
9 5/8 152
9 3/4 142
10 5/8 - 90

MM MM 3 50 54 MASHOE
Mapsworth Nevada
Corner Virginia & Vexley
BOTH SEAMOUS
BEMO MA 90205
5550 CITREEL DR
5338