



WELL DRILLERS REPORT

Please complete this form in its entirety

Intent to Drill Card # 1378

1. OWNER Dennis Sanada (ADDRESS 40-310-48
 1163 Calvados Drive (of Well: Corner of Thomas Creek Rd. and
 Sparks, Nv. 89431 Palmira Street - Reno, Nv.

2. LOCATION NW 1/4 SW 1/4 Sec. 7 T. 18 N/S R. 20 E. WASHOE County
 PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Overburden		0	6	6
Cobbles, boulders and loose sands		6	59	53
Coarse volcanic sands - multi-colored		59	78	19
Tan colored clay Layer \emptyset Tightly compact		78	89	11
Coarse Volcanic Sands - lightly cemented with Brown light clay		89	96	7
Cobbles with clay stringers Tan with coarse sands		96	142	53
T.D. 142 ft.				
Casing has 4' Blank on bottom of Perf. for cleaning & development of Well				

8. 10 5/8" - WELL CONSTRUCTION

Diameter hole 8 3/4 inches Total depth 142 feet
 Casing record 6 5/8" casing .188
 Weight per foot 12.92 Thickness .188

Diameter	From	To
6 5/8 inches	+ 1 feet	142 feet
.....inchesfeetfeet

Surface seal: Yes No Type Slurry
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 142 feet

Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3

From	feet to	feet
From 118	feet to 138	feet
From	feet to	feet
From	feet to	feet
From	feet to	feet

Date started 2/24, 19 83
 Date completed 2/26, 19 83

7. WELL TEST DATA			
Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew Well for 1 hr., 30 mins. to clean and develop - 225# Air, at 600 CFM			

BAILER TEST			
G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level

Flow 20 + G.P.M.

Water temperature cool ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICE, INC.

Address 2255 GLENDALE AVE. - SPARKS, NV.

Nevada contractor's license number 15291

Nevada driller's license number 1132

Signed *Roger M. Thrall*
 Roger M. Thrall
 Date 2/28/83