WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 24444
Permit No.
Basin

3-84

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Steve Brockner ADDRESS Huntington Circle Reno

2. LOCATION ¼ ¼ Sec. 21 T. 19 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. geo PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy brown clay		0	48	48'
blue clay		48	75	27'
purple clay		75	85	10'
brown clay		95	130	45'
blue gray clay		130	170	40'
rock gray	X	170	190	20'
ash purple broken rock	X	190	215	15'

Date started Jan 31, 19 83
Date completed Feb 4, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	20	nc	5 hrs

BAILER TEST
G.P.M. 20 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 215 feet
Casing record
Weight per foot Thickness 188

Diameter	From	To
8 inches	0 feet	215 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 76 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation machine
Size perforation 1/8 X 4
From 190 ~~[illegible]~~ feet to 215 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 15 Feet below land surface
Flow G.P.M.
Water temperature 190 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas R Peck
Address 6154 Stone Hill S Salem, Oregon
Nevada contractor's license number 14170
Nevada driller's license number 1259
Signed Thomas R Peck
Date Feb 10, 83

USE ADDITIONAL SHEETS IF NECESSARY

O-627