WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24462
Permit No.
Basin 108

1. OWNER RICHARD HANSEN ADDRESS 122 GALLAGHER YERINGTON, NEV.

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 14 N/S R. 25 E. LYON County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY, SAND, ROCK		0	3	3
SAND, CLAY, ROCK		3	20	17
SAND + ROCK		20	28	8
SAND, ROCK + CLAY		28	38	10
SAND + ROCK FINE		38	97	59
GRAVEL, SAND, ROCK		93	122'6"	29'6"

Date started 1-17, 1983
Date completed 1-22, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	25	10	2 HR

BAILER TEST
G.P.M. 20 Draw down 8 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 123'6" feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
6 inches	(+) 1 feet	122'6" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 122'6" feet

Perforations:
Type perforation FACTORY SANDED
Size perforation 3/32" x 3" x 6 ROWS
From 102'6" feet to 122'6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 38' Feet below land surface 37'
Flow — G.P.M. —
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name OGDEN BROS' DRILLING
Address 162 N. BYBEE LN. YERINGTON, NEV. 89447

Nevada contractor's license number 15646

Nevada driller's license number 870

Signed Billy Ogden

Date 2-7-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627