

Log No. 24472  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1549

PRINT OR TYPE ONLY

1. OWNER Phil CARTER ADDRESS AT WELL LOCATION PINTO CIRCLE  
 MAILING ADDRESS P.O. Box 383  
Minden, Nev. 89423  
 2. LOCATION  $\frac{1}{4}$  Sec. 24 T. 12 S. R. 20 E DOUGLAS County  
 PERMIT NO. 2 RHuenstroph Subdivision Name  
 Issued by Water Resources Parcel No.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material            | Water Strata | From | To  | Thick-ness |
|---------------------|--------------|------|-----|------------|
| Clay & SAND         |              | 1    | 7   |            |
| Clay                |              | 7    | 17  |            |
| Clay & Gravel       |              | 17   | 39  |            |
| Gravel/Cobblestones |              | 39   | 57  |            |
| Cobblestones/CLAY   |              | 57   | 85  |            |
| Gravel & clay       |              | 85   | 103 |            |
| GRAVEL              |              | 103  | 112 |            |
| Clay & Gravel       |              | 112  | 117 |            |
| Gravel & SAND       |              | 117  | 130 |            |

8. WELL CONSTRUCTION  
 Diameter hole 8 5/8 inches Total depth 130' feet  
 Casing record 130'  
 Weight per foot \_\_\_\_\_ Thickness 188  

| Diameter            | From          | To              |
|---------------------|---------------|-----------------|
| <u>8 5/8</u> inches | <u>0</u> feet | <u>130</u> feet |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |

 Surface seal: Yes  No  Type Cement  
 Depth of seal 5-8 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation FACTORY slot  
 Size perforation 3" x 1/16"  
 From 105 feet to 125 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started JAN. 11, 1983  
 Date completed JAN. 20, 1983

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST  
 G.P.M. 18 Draw down 12 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 87 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Hi-Sierra Drilling Contractor  
 Address P.O. Box 901 Minden, Nev. Contractor  
 Nevada contractor's license number \_\_\_\_\_  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 763 Actual Driller  
 Signed Anthony Kowzback Contractor  
 Date Jan 23, 1983