WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24484
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 0119

1. OWNER William, Joseph Richter
MAILING ADDRESS 3060 Hyway 395 South Carson City - Nev - 89701
ADDRESS AT WELL LOCATION 3060 Hyway 395 South Carson City -

2. LOCATION SE ¼ SW ¼ Sec. 19 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. 37953 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☑ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sand	✓	5	11	6
Clay		11	12	1
Gravelly Clay		12	15	3
Sand, Grav + Cobbles	✓	15	19	4
Alternating layers sand gravel & Clay		19	30	11
Clay		30	34	4
Course sand & Gravel	✓	34	41	7
Sand, grav, tan Clay streak		41	61	20
Same		61	67	6
Clay		67	73	6
Sand & gravel	✓	73	83	10
Clay		83	95	12
Alt. layers, sand, grav. Clay	-	95	115	20
Blue Clay		115	121	6
Sand & Gravel		121	129	8
Blue Clay		129	136	7
Alt. layers, sand, grav. Clay	✓	136	152	16
Blue Clay		152	158	6
Alt. layers, sand, grav + Clay	✓	158	174	16
Blue Clay		174	182	8
Alt. layers, sand, grav + Blue Clay	✓	174	400	226

Date started Oct 1, 1982
Date completed Feb 25, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No	Pump	Test	Made -

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 24" inches Total depth 400 - feet
Casing record 16" OD -
Weight per foot 47.22 LBS Thickness .281

Diameter	From	To
32" hole inches	0 feet	30 feet
24" + Conductor inches	- feet	30 feet
16" inches	+ 1 feet	400 - feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type
Depth of seal 30 FT. - Warder Granted feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 0 feet to 400 feet

Perforations:
Type perforation Milled Slot
Size perforation 3/32
From 60 feet to 400 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow Apr - 700 G.P.M. ? P.S.I.
Water temperature Cold ° F. Quality ?

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling Co (Contractor)
Address Rt 3 Box 47 A Susanville, Cal 96130 (Contractor)
Nevada contractor's license number 4739 A -
Nevada contractor's drillers number
Nevada driller's license number 249 (Actual Driller)
Signed [signature] Enloe (Contractor)
Date 3/20/83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434