

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO 1054

1. OWNER Shorty Nowlin ADDRESS AT WELL LOCATION 1285 Melbourne Johnson Lane
 MAILING ADDRESS _____
 2. LOCATION 1/4 Sec. 28 T. 14 S. R. 20 E. Douglas County Johnson Lane
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & CLAY		1	18	
SAND	X	18	23	
CLAY		23	29	
SAND & CLAY		29	46	
CLAY		46	57	
SAND & CLAY		57	73	
CLAY		73	92	
SAND	X	92	107	
CLAY		107	110	

8. WELL CONSTRUCTION
 Diameter hole 8 5/8 inches Total depth 110 feet
 Casing record 110'
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>8 5/8</u> inches	<u>1</u> feet	<u>110</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory slot
 Size perforation 3x 1/16
 From 890 feet to 110 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Flow _____ G.P.M. 25 P.S.I.
 Water temperature _____ ° F. Quality _____

Date started 2-15-83, 19____
 Date completed 2-18-83, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kawchack Drilling Inc. Contractor
 Address Box 536 Gardnerville, Nev. Contractor
 Nevada contractor's license number _____
 Nevada contractor's drillers number _____
 Nevada driller's license number 763 Actual Driller
 Signed Steve Kawchack Contractor
 Date 2-18-83

BAILER TEST
 G.P.M. 25 Draw down 18 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours