WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 24495
Permit No. 45241
Basin TR. CANYON SEG. 6-91

WELL DRILLERS REPORT

Please complete this form in its entirety

Alkali Meadows

1. OWNER IDM Enterprises ADDRESS Old Hwy 40 Nev. Nev
1169 Palomar Rd PR 11 out PARCEL # 35-C-3C-1
Pacoima, Calif 91334
2. LOCATION S.W. ¼ S.W. ¼ Sec. 9 T. 19 N/S R. 18 E. Lincoln County
PERMIT NO. 45241

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☐ Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Large sand rocks & gravel		3	34	31
Gray clay		34	48	14
Cafe/red stuff		48	190	142
Red Basalt				
Colorado Basalt Rock		190	220	30
Black basalt Rock		220	240	20
Fractured basalt	X	240	263	23
Red Vol. Rock	X	263	272	9
Black Vol. Rock		272	286	14
Red Vol. Rock	X	286	291	5
Black Vol. Rock		291	300	9
Bottom perforated				
hole will be lined				
taken Test Pump				

Date started 3-12, 1983
Date completed 3-25, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3400	250	15/3	72 hr

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 300 feet
Casing record
Weight per foot 8 16 40 Thickness 188
Diameter 6 5/8 12 7 From To 55

Diameter	From	To
8 5/8 inches	0 feet	235 feet
6 5/8 inches	232 feet	300 feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 186 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 186 feet to 235 feet

Perforations:
Type perforation factory wound
Size perforation 3/16 x 3/32
From ..... feet to ..... feet
From 192 feet to 235 feet
From ..... feet to ..... feet
From 232 feet to 300 feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 97 Feet below land surface
Flow ..... G.P.M. Approx 250
Water temperature Cool ° F. Quality Clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul E. Williamson
Address 225 S. Pitman, Sparks
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul E. Williamson
Date 3-27-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627