

Log No. 24596

Permit No. \_\_\_\_\_

Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1366

PRINT OR TYPE ONLY

1. OWNER BARRY LEE ADDRESS AT WELL LOCATION Cimarron Drive  
 MAILING ADDRESS 11048 Zeolite Way Reno, Nv. 89506  
 2. LOCATION SW 1/4 NW 1/4 Sec 24 T 2 E 18 WASHOE County  
 PERMIT NO. 086-233-18 Washoe Ranches  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clays with D.G.				
Sands		0	305	305
Green clays mixed with brown stringers of brown clay and D. G.	X	305	325	20
T.D. 325 ft.				

8. 10" total depth WELL CONSTRUCTION

Diameter hole 10 inches Total depth 230 feet  
 Casing record 6 5/8" - .156 & .188 perf.  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>18"</u>	<u>230</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type concrete  
 Depth of seal 56 feet  
 Gravel packed: Yes  No   
 Gravel packed from 56 feet to 230 feet

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 X 3  
 From 192 feet to 230 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level \_\_\_\_\_ feet below land surface  
 Flow 10 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICE, INC.  
 Address 2255 GLENDALE AVE. - SPARKS, NV. 89431  
Contractor

Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
Actual Driller

Signed Roger M. Thrall Contractor  
 Date 4/15/83

Date started 4-14, 1983  
 Date completed 4-15, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Blew Well with 250# at 650 CFM to clean and develop.  
 One hour development.

BAILER TEST

G.P.M.	Draw down	feet	hours