

**WELL DRILLERS REPORT**

NOTICE OF INTENT NO. 0594

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER ROBERT & DEBROAH WEAVER ADDRESS AT WELL LOCATION same  
 MAILING ADDRESS 1551 DEER RUN ROAD  
CARSON CITY, NV 89701  
 2. LOCATION NW 1/4 NW 23 T 15 N/S R. 20 E WASHO CARSON County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. replacement PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown sand fine 1/32"		0	16	16
multi-colored sand & gravel fine 3/4"		16	60	44
cemented sand & gravel fine 3/4"		60	78	18
brown sandy clay w/ gravel 80% clay		78	116	38
mostly sand & gravel w/ layers of clay	XX	116	119	3
sand & gravel w/ 10% clay		119	121	2
brown sandy clay		121	131	10
cemented sand w/ fractures some gravel	XX	131	137	6
brown sandy clay		137	144	7
fractured sandstone—brown, red, white—mixed w/ green & brown clay		144	150	6
fractured sandstone w/ crystals & chaulk		150	154	4
fractured sandstone	XX	154	160	6
brown clay		160	165	5

8. WELL CONSTRUCTION  
 Diameter hole 12 1/4 inches Total depth 162 feet  
 Casing record 8 5/8" x .188 wall  
 Weight per foot 16.94 Thickness \_\_\_\_\_  
 Diameter From To  
8 5/8 inches +1 feet 162 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type cement grout  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to 162 feet  
 Perforations:  
 Type perforation milled  
 Size perforation 1/8" x 3"  
 From 121 feet to 162 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started September 20, 1982  
 Date completed January 8, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1 hp subm	<u>22 1/2</u>	<u>7</u>	<u>2</u>

9. WATER LEVEL  
 Static water level 105 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 120 ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SAGE BROS DRILLING CO., INC.  
 Contractor  
 Address 7800 N. VIRGINIA STREET RENO, NV 89506  
 Contractor  
 Nevada contractor's license number 7462A  
 Nevada contractor's drillers number 774  
 Nevada driller's license number 953  
 Actual Driller

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

Signed [Signature] Contractor  
 Date March 1, 1983