

OFFICE USE ONLY
 Log No. 24564
 Permit No. 84
 Basin 84

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2594

1. OWNER B. C. THRALL ADDRESS AT WELL LOCATION 5800-2300 (TWIN SPRINGS) ROAD
 MAILING ADDRESS 2255 GLENDALE AVE. SPARKS, NV. 89431 PALOMINO VALLEY - Reno - 89510
 2. LOCATION NE 1/4 NE 1/4 Sec. 2635 T. 22 N/S R. 21 E Washoe County
 PERMIT NO. 077-160-2836 Parcel No. Palomino V. Unit 1 26-2-1-13 part 2 Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	126	126
Red clay Clay and Volcanic Rock		126	190	64
Brown clay - Cemented Sands				
Rock chips - brown & green		190	206	16
Green clays - cemented Sands				
Rock chips, multi-colored water bearing sands		206	246	40
T.D. - 246 ft.				

8. 10" -- WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 246 feet
 Casing record 6 5/8 .156
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>±.2</u> feet	<u>246</u> feet
.....inchesfeetfeet

 Surface seal: Yes No Type Grout
 Depth of seal 56 feet
 Gravel packed: Yes No
 Gravel packed from 56 feet to 246 feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From 206 feet to 246 feet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet

9. WATER LEVEL
 Static water level 96 feet below land surface
 Flow 15 G.P.M. P.S.I.
 Water temperature cool ° F. Quality good

7. WELL TEST DATA
 Date started 4-16, 1983
 Date completed 4-18, 1983

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING & WELL SERVICE, INC.
 Address 2255 GLENDALE AVE., SPARKS, NV. 89431
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller
 Signed R. Michael
Roger M. Thrall Contractor
 Date 4-20-83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew & surged well for 2 hours to clean and develop, using <u>50#</u> air at 600 CFM			

BAILER TEST

G.P.M.	Draw down	feet	hours