

OFFICE USE ONLY
 Log No. 24576
 Permit No. 22290
 Basin _____

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 1762

1. OWNER REX COLLINGWOOD ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS EUREKA, NEV 89316

2. LOCATION NW 1/4 NW 1/4 Sec 32 T 20 N/S R 53 E EUREKA County _____
 PERMIT NO. 22290 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
FREE PEA GRAVEL		238	247	9
HARD ROCK		247	249	2
ROCK GRAVEL		249	253	4
ROCK GRAVEL BROWN SANDSTONE		253	256	3
ROCK-PEA GRAVEL		256	266	10
PEA GRAVEL (BK) SOME ROCK		266	280	14
FREE GRAVEL SEVERAL COLORS		280	285	5
LT. BR. CLAY S/GRAVEL		285	289	4
ROCK GRAVEL		289	295	6
HD. ROCK ALTIMITE (BLK)		295	296	1
CEMENT GRAVEL		296	298	2
ROCK GRAVEL		298	301	3
GRAVEL		301	305	4
FREE GRAVEL-SEVERAL COLOR		305	307	2
FREE GRAVEL-SEVERAL COLORS SOME LT. BR. CLAY		307	308	1

8. WELL CONSTRUCTION
 Diameter hole 16 inches Total depth 308 feet
 Casing record 14
 Weight per foot _____ Thickness 1/4
 14 ^{Diameter} PERF 208 From _____ To 308 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation MILL SLOT
 Size perforation 1/8 x 3
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From SEE ABOVE feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-4-83, 19_____
 Date completed 4-18-83, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 113 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HUMBOLDT DRILLING & PUMP CO., INC.
 Address P.O. BOX 592, WINNEMUCCA, NEV 89445
 Contractor
 Nevada contractor's license number 015234
 Nevada contractor's drillers number C-23
 Nevada driller's license number 961
 Signed [Signature] Actual Driller
 Date 4-28-83 Contractor