WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 24587
Permit No.
Basin

NOTICE OF INTENT NO. 1364

1. OWNER BRUCE WICKS
MAILING ADDRESS 1755 E. PLUMB LANE
RENO, NV. 89502

ADDRESS AT WELL LOCATION 5595 Wintergreen St.

2. LOCATION ¼ ¼ Sec. 2 T 17 N/S R. 19 E : WASHOE County
PERMIT NO. (Issued by Water Resources) 045-535-04 (Parcel No.) = Lot #226 - Galena Terrace Estates (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden - cobbles & boulders		0	6	6
Volcanic sands and some clays		6	179	173
Volcanic Rock Chips - some Clay Stringers		179	185	
Water bearing strata	X			
T. D. - 185 ft.				

Date started 4-29, 19 83
Date completed 5-2, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well at 175# at 650 CFM to clean and develop			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 183 feet
Casing record 6 "
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+ 18" feet	183 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

10 5/8" - 50'

Surface seal: Yes [X] No [ ] Type grout
Depth of seal 56 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 56 feet to 183 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 161 feet to 183 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 98 feet below land surface
Flow 15+ G.P.M. ..... P.S.I.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICE, INC. (Contractor)
Address 2255 GLENDALE AVE. - SPARKS, NV. 89431 (Contractor)
Nevada contractor's license number 15291
Nevada contractor's drillers number 1132
Nevada driller's license number 1132 (Actual Driller)
Signed Roger M Thrall (Contractor)
Roger M. Thrall
Date 5/4/83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434