

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2338

PRINT OR TYPE ONLY

1. OWNER KEN JOLLY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1073 ROCK BLVD. 2336 WEST WIND CIRCLE  
SPARKS, NV. 89431 RENO, NV. 89511  
 2. LOCATION NE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 34 T. 18 N/S R. 21 E WASHOE County  
 PERMIT NO. 17-073-38 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Altered Volcanic Rock, orange and yellow		0	92	92
YELLOW Clay		92	107	15
Altered Volcanic Rock		107	135	28
Yellow Clay Layer		135	142	7
Altered Volcanic Rock, Dark in color, some Dark Red		142	180	38
Gray Volcanic Ash, Type clay		180	220	40
Green Volcanic Ash type clay		220	295	75
Hard fractured Rust-colored Rock		295	325	30
T.D. - 325 ft.				

8. WELL CONSTRUCTION  
 Diameter hole 7 7/8 inches Total depth 323.5 feet  
 Casing record 6 5/8 - 156  
 Weight per foot 10.78 Thickness 156  
 Diameter 6 5/8 inches From +18" feet To 323.5 feet  
 Surface seal: Yes  No  Type Grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 323.5 feet  
 Perforations: Factory  
 Type perforation \_\_\_\_\_  
 Size perforation 3/32 X 3  
 From 301.19 feet to 323.50 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Flow 15 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE, INC.  
 Contractor  
 Address 2255 GLENDALE AVE. SPARKS, NV. 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1379  
 Actual Driller  
 Signed Roger M. Thrall Contractor  
 Date 5-9-83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew Well with 170# at 600 CFM to clean and develop for 2 1/2 hours.			

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours