WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 24592
Permit No. ~~43268~~ 43271
Basin [redacted]

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1761

1. OWNER STENTON FARMS
MAILING ADDRESS BOX 126
EUREKA, NEV 89316

ADDRESS AT WELL LOCATION [redacted]

2. LOCATION NW ¼ NW ¼ Sec. 17 T. 21 N/S R. 53 E Eureka County
PERMIT NO. ~~43268~~ 43271 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LG. GRAVEL		160	165	5
FREE GRAVEL		165	167	2
LG. GRAVEL-SEVERAL COLOR		167	178	11
FREE PEA GRAVEL		178	180	2
GREY CLAY		180	186	6
CLAY-SM. GRAVEL		186	190	4
LT. BR. CLAY		190	194	4
BR. CLAY-SM. GRAVEL		194	197	3
FREE GRAVEL		197	206	9
GRAVEL ROCKS		206	210	4
FREE GRAVEL SAND-SM.ROCK		210	237	27
SMALL ROCKS-GRAVEL		237	240	3
GRAVEL, SAND, ROCKS		240	250	10
FREE GRAVEL		250	256	6
CEMENT GRAVEL		256	258	2
FREE GRAVEL-SAND		258	263	5
HD. ROCK		263	265	2
FREE GRAVEL & SAND		265	275	10
LG. GRAVEL -SEVERAL COLOR		275	291	16
BR. CLAY		291	292	2
LG. GRAVEL & ROCKS		292	300	8
[redacted]				

Date started 4-8-83, 19
Date completed 4-19-83, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 16 inches Total depth 300 feet
Casing record 14
Weight per foot Thickness ¼

Diameter	From	To
14 Perf inches	151 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Mill Slot
Size perforation 1/8
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 95 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HUMBOLDT DRILLING & PUMP CO. (Contractor)
Address P.O. BOX 592 WINNEMUCCA, NEV 89445 (Contractor)
Nevada contractor's license number 015234
Nevada contractor's drillers number C-23
Nevada driller's license number 961 (Actual Driller)
Signed [signature] (Contractor)
Date 5-10-83

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434